



NetBotz[®] Door Switch Sensors for APC[®] Racks (NBES0313) Installation Instructions

Inventory



Switch with connected 1.57-m (62-in) door switch sensor cable



Magnet



M3 hex nut (2)



6-32 x 5/16-in screw (4)



Wire clip (8)




63.5-mm (2.5-in) dual adhesive tape (2)



203-mm (8-in) tie wrap (5)



Adhesive cable tie holder (5)



RJ-45 coupling (1)

Installation




Caution: Make sure you connect this sensor to a **Sensor** port on applicable NetBotz products. See your NetBotz product documentation for details.




Note: You can extend the length of the sensor cable up to 30.5 m (100 ft) using the RJ-45 coupling and standard CAT-5 cabling.

1 Front Door of NetShelter® SX Enclosure



2 Rear Door of NetShelter SX Enclosure



Customer support and warranty information is available at the APC Web site, www.apc.com.

990-4589
9/2011